



WESTERN ANALYTICAL LABORATORY TEST REPORT

REPORT NO: 50413 CLIENT: Frank Serrao
 DATE RECEIVED: October 16, 2007 4865 Leeds Street
 DATE REQUIRED: October 17, 2007 REFERENCE: 4865 Leeds Street
 Simi Valley, CA 93063

SUBJECT: Polarized Light Microscopy Analysis for Asbestos; 5 samples
 METHODOLOGY: "Method for the Determination of Asbestos in Bulk Building Materials"
 (EPA 600/R-93/116)*
 ACCREDITED: National Institute of Standards and Technology (NVLAP) # 200037

SAMPLE ID NUMBER	SAMPLE LOCATION AND DESCRIPTION	VISUAL DESCRIPTION	ASBESTIFORM MINERALS	OTHER FIBROUS MATERIALS	NON-FIBROUS MATERIALS
01	Blue floor tile	Blue granular/ fibrous Non-friable	Chrysotile 15%	None Detected	Granular Minerals Resin
02	Mastic under Sample #02	Black sticky Non-friable	None Detected	None Detected	Granular Minerals Organics (tar)
03	White floor tile	White granular/ fibrous Non-friable	Chrysotile 15%	None Detected	Granular Minerals Resin
04	Mastic under Sample #03	Black sticky Non-friable	None Detected	None Detected	Granular Minerals Organics (tar)
05	Dark brown floor tile	Dark brown granular/ fibrous Non-friable	Chrysotile 15%	None Detected	Granular Minerals Resin

t: Trace > 1% = greater than 1% < 1 = less than 1%

 Optical Microscopist

 Mike Maladzhikyan, Laboratory Director

This report only applies to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Western Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Western Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government.